

# CERTIFICATE OF PRODUCT CERTIFICATION

## TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2020010302293437

Valid from: May.22,2020

Valid until: Oct.19,2031

**NAME AND REGISTERED ADDRESS OF THE APPLICANT** SOCOMEC S.A  
1, Rue De Westhouse 67230 Benfeld Cedex France

**NAME AND REGISTERED ADDRESS OF THE MANUFACTURER** SOCOMEC S.A  
1, Rue De Westhouse 67230 Benfeld Cedex France

**NAME AND LOCATION OF THE FACTORY** SOCOMEC S.A  
1, Rue De Westhouse 67230 Benfeld Cedex France

**PRODUCT NAME, MODEL AND SPECIFICATION** FUSE COMBINATION SWITCH  
FUSERBLOC 1250A; Uimp:12kV; Ui:1000V; Ith: 1250A; Ue: AC690V; Ie: 1250A; Iq:80kA;  
Utilization Category: AC-22B; Poles : 2P,3P,4P;

**THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS** GB/T14048.3-2017

**TYPE OF CERTIFICATION SCHEMES** Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.  
The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



SIGN BY

陈昕

SIGNATURE

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE