

**IEC****IECEE**

Ref. Certif. No.

CN55215

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

SWITCH DISCONNECTOR FUSE

Name and address of the applicant

SOCOME S.A.S

1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the manufacturer

SOCOME S.A.S

1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the factory

SOCOME S.A.S

1, Rue De Westhouse 67230 Benfeld Cedex France

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Uimp:8kV; Ui:800V; Ith:25A,32A; Ue:AC690V; Ie:25A,32A; Iq:100kA; AC-23A; 3P,3P+N(3 protected poles with an uninterrupted neutral pole); Iq:100kA; Rated frequency:50/60Hz

Trademark / Brand (if any)

SOCOME

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

FUSERBLOC CD 25A, FUSERBLOC CD 32A

Additional information (if necessary may also be reported on page 2)

IEC 60947-3:2020 in conjunction with IEC 60947-1:2020

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2021CQC-099755

This CB Test Certificate is issued by the National Certification Body

**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Nov.16,2021

Signature:

Xie ZhaoXu

**CB 0065394**