



Ref. Certif. No.

CN55350

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

**CB TEST CERTIFICATE**

Product

SWITCH DISCONNECTOR

Name and address of the applicant

SOCOMECS.A.S  
1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the manufacturer

SOCOMECS.A.S  
1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the factory

SOCIETE TIMELEC SARL  
ZONE INDUSTRIELLE CHEBEDA ROUTE DE FOUCHANA  
NAASSEN 1135 NAASSEN GOUVERNORATDE BEN AROUS,  
Tunisia

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Uimp: 8kV;Ui: 800V;lth: 125A(SIRCO 125A),160A(SIRCO 160A),200A(SIRCO CD 200A);  
Ue: AC415V;Ie: 125A(SIRCO 125A),160A(SIRCO 160A),200A(SIRCO CD 200A);  
Icw: 7kA/1s;Icm(Peak): 11.9kA; Iq: 50kA, 100kA;Utilization category: AC-23A,AC-22A;Number  
of poles:3P,4P;Rated frequency :50/60Hz

Trademark / Brand (if any)

SOCOMECS

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

SIRCO 125A,SIRCO 160A,SIRCO CD 200A;

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-3:2020 in conjunction with IEC 60947-1:2020

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2021CQC-099869

This CB Test Certificate is issued by the National Certification Body

**CHINA QUALITY CERTIFICATION CENTRE**Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China  
Tel: +86-10-83886666 Fax: +86-10-83886282  
website: <http://www.cqc.com.cn>

Date: Dec.21,2021

Signature:

Xie ZhaoXu

CB 0066097